



- Charger for lead-acid batteries (flooded, Gel and AGM) and Li-ion batteries (lithium iron and lithium manganese) (Note.1)
- 2/3/8 stage charging selectable on output panel (Note 5)
- Built-in battery rescue function
- Universal AC input / Full range
- · Controlled by microprocessor
- Built-in active PFC function PF>0.95
- Protection: Reverse Polarity / Short circuit / Over voltage / Over temperature
- 3 color LED loading indicator
- \* Built-in remote ON-OFF control
- 2-Bank charger
- Temperature compensation function
- FAN on/off control (depends on charging current)
- 3 years warranty








# **SPECIFICATION**

MODEL		PB-1000-12	PB-1000-24	PB-1000-48	
	BOOST CHARGE VOLTAGE Vboost	14.4V	28.8V	57.6V	
	FLOAT CHARGE VOLTAGE Vfloat	/OLTAGE Vfloat   13.8V   27.6V   55.2V			
	OUTPUT CURRENT	60A	34.7A	17.4A	
OUTPUT	RECOMMENDED BATTERY CAPACITY(AMP HOURS)(Note 4)	200 ~ 600Ah	120 ~ 350Ah	60 ~ 175Ah	
	BATTERY TYPE	Open & Sealed Lead Acid			
	LEAKAGE CURRENT FROM	.4. A			
	BATTERY (Typ.)	<1mA			
	VOLTAGE RANGE	90 ~ 264VAC 127 ~ 370VDC			
	FREQUENCY RANGE	47 ~ 63Hz			
	POWER FACTOR (Typ.)	0.95/230VAC 0.98/115VAC at full load	d		
INPUT	EFFICIENCY (Typ.)	85%	88%	89%	
	AC CURRENT (Typ.)	12A/115VAC 5.2A/230VAC			
	INRUSH CURRENT (Typ.)	25A/115VAC 50A/230VAC			
	LEAKAGE CURRENT	<3.5mA/240VAC			
	OVER VOLTAGE	16~18V	32 ~ 35V	64.5 ~ 69.5V	
PROTECTION	OVER VOLIAGE	Protection type : Shut down o/p voltage, re-power on to recover			
	OVER TEMPERATURE	Shut down o/p voltage, recovers automatically after temperature goes down			
	SHORT CIRCUIT	YES, protected by internal circuit			
	REVERSE POLARITY	YES, protected by internal circuit			
	REMOTE CONTROL	Open: Normal work Short: Stop Charging			
	BATTER BANKS	2 banks (A & B)			
FUNCTION	FAST CHARGE	2/3/8 stage selectable			
1 011011011	CHARGER OK	Relay contact rating(max.): 30V/1A resistive; "Short" when the unit is working properly, "Open" when the unit is failure or the protection function is activating			
	OUTPUT OK	Relay contact rating(max.): 30V/1A resistive; "Short" when the battery is full, "Open" when the battery is still charging			
	TEMPERATURE COMPENSATION	By NTC, compensate both banks at the sa	ame time		
	WORKING TEMP.	-20 ~ +60 $^{\circ}$ C (Refer to "Derating Curve")			
	WORKING HUMIDITY	20 ~ 90% RH non-condensing			
ENVIRONMENT	STORAGE TEMP., HUMIDITY	-40 ~ +85°C, 10 ~ 95% RH			
	TEMP. COEFFICIENT	$\pm 0.05\%$ °C (0~50°C)			
	VIBRATION	10 ~ 500Hz, 2G 10min./1cycle, 60min. each along X, Y, Z axes			
	SAFETY STANDARDS	UL60950-1, TUV EN60950-1 approved			
SAFETY &	WITHSTAND VOLTAGE	I/P-O/P:3KVAC I/P-FG:2KVAC O/P-F	G:0.5KVAC		
EMC	ISOLATION RESISTANCE	I/P-O/P, I/P-FG, O/P-FG:100M Ohms / 50	0VDC / 25°C / 70% RH		
(Note 3)	EMC EMISSION	Compliance to EN55022 (CISPR22), EN61000-3-2,-3			
	EMC IMMUNITY	Compliance to EN61000-4-2,3,4,5,6,8,11	, EN55024, light industry level, criteria A		
	MTBF	127.4K hrs min. MIL-HDBK-217F (25°C)			
OTHERS	DIMENSION	300*184*70mm(L*W*H)			
	PACKING	3.5Kg; 4pcs/15Kg/1.83CUFT			
NOTE	All parameters NOT special     The power supply is consided EMC directives.     This is Mean Well's sugges	edification may be required for different battery specification. Please contact battery vendor and MEAN WELL for details.  Illy mentioned are measured at 230VAC input, rated load and 25°C of ambient temperature.  In the final equipment must be re-confirmed that it still meets at the drange. Please consult your battery manufacturer for their suggestions about maximum charging current limitation.  It is election when the charger is used to charge the batteries and power the loads in the same time.			





※ LED Loading Indicator Status Table

Color	Steady	Flashing
Red	Abnormal status	
Orange		Charging
Green	Full	Charging


※ Control Pin No. Assignment(CN100): HRS DF11-10DP-2DS or equivalent




Mating Housing	HRS DF11-10DS or equivalent
Terminal	HRS DF11-**SC or equivalent

Pin No.	Function	Description
1,2	RY13	RY13 : Battery Bank A OK relay.  Relay contact rating(max.) : 30V/1A resistive. ; "Short" when the battery A is full, "Open" when the battery A is still charging.
3,4	RY14	RY14: Battery Bank B OK relay.  Relay contact rating(max.): 30V/1A resistive.; "Short" when the battery B is full, "Open" when the battery B is still charging.
5,6	RY15	RY15: Charger OK relay.  Relay contact rating(max.): 30V/1A resistive.; "Short" when the unit is working properly, "Open" when the unit is failure or the protection function is activating.
7	GND	NTC / GND : Temperature sense Temperature sensor comes along with the charger can be connected to the unit to allow temperature compensation of the
8	$NTC(5K\Omega)\\RTH$	charging voltage.  If the temperature sensor is not used, the charger still works normally.
9,10	RC-/RC+	Remote ON/OFF function. Turn the output on and off by electrical or dry contact between pin 10 (RC+) and pin 9(RC-). "Open": Normal work; "Short": Stop charging






### ■ Derating Curve




## ■ Charging Curve



State	PB-1000-12	PB-1000-24	PB-1000-48
Constant Current	60A	34.7A	17.4A
Vboost	14.4V	28.8V	57.6V


© Suitable for lead-acid batteries (flooded, Gel and AGM) and Li-ion batteries (lithium iron and lithium manganese).



State	PB-1000-12	PB-1000-24	PB-1000-48
Constant Current	60A	34.7A	17.4A
Vboost	14.4V	28.8V	57.6V
Vfloat	13.8V	27.6V	55.2V

© Suitable for lead-acid batteries (flooded, Gel and AGM) and Li-ion batteries (lithium iron and lithium manganese).





- © Suitable for lead-acid batteries (flooded, Gel and AGM).
- (Soft Start) provide battery rescue function.


#### 2,3, or 8 Stage Charging Select

(1) The charger features user selectable 2,3, or 8 stage charging.

The charging profile is selected by moving the slide switch on the back panel.

Switch	Charging mode	
Right	2 stage charging	
Middle	3 stage charging	
Left	8 stage charging	

(2)Please choose the "3 stage" selection when the charger is used to charge the batteries and power the loads in the same time.



	CN100			
1	RY13	RY13	:	
	RY14	RY14		
	RY15	RY15		
	GND	RTH		
9	RC-	RC+	1	


### **■** Function Manual

## 1.Remote Control

The charger can be turned  $\ensuremath{\mathsf{ON}}\xspace/\ensuremath{\mathsf{OFF}}\xspace$  by using the

"Remote Control" function.

Between RC+(pin10) and RC-(pin9)	Charger
SW Open	ON
SW Short	OFF




CN100





#### 2.Two Battery Banks (2/8 stage only)

The charger may be hooked up two battery banks (A and/or B). Connect the battery bank(s) as below. If you are connecting 2 battery banks in the same time, keep in mind that they must share a common ground.

NOTE: The charger will charge bank A first then bank B if both channels are connected.









### 3.Charger OK Relay(RY15)

Charger	Between pin5 and pin6(RY15)
Normal work	ON (Short)
Failure or the protection function is activating	OFF (Open)






### 4.Output OK Relay(RY13 & RY14)


## 1.Bank A OK (RY13)

Bank A	Between pin1 and pin2(RY13)	Color of LED A
Battery A Full	ON (Short)	Green
Charging	OFF (Open)	Orange

### 2.Bank B OK (RY14)

Bank B	Between pin3 and pin4(RY14)	Color of LED B
Battery B Full	ON (Short)	Green
Charging	OFF (Open)	Orange






#### 5.Temperature Compensation

Temperature sensor comes along with the charger can be connected to the unit to allow temperature compensation of the charging voltage.

If the temperature sensor is not used, the charger still works normally.



The temperature sensor can either be attached to the battery or placed in its surrounding environment.

### ■ Installation Manual

Please refer to the manual of PB-1000.